

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 09

Dated: 16/06/25

It is certified that an inspection team headed by Dr. Nandah Singh

(Name of Officers with designation) from Dy. CMO PHED

inspected the Deedar Singh Public Uchchatar Madhyamik Vidyalaya
Jajau, Fatehpur Sikri, Kiraoli, Agra

(Name & Address of the school) on 13/06/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. OHM 20250612001 dated 16/06/25

of OHM Laboratory Private Ltd. (PHED Lab) certified that the

Deedar Singh Public Uchchatar (Name of school) has safe drinking water
Madhyamik Vidyalaya Jajau, Fatehpur Sikri, Kiraoli Agra

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31 March 2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: Chief Medical
Officer, Agra Near Central Jail Road
Agra

To

Deedar Singh Public
Uchchatar Madhyamik Vidyalaya Jajau,
(Name & Address of the Institution) Fatehpur Sikri, Kiraoli Agra

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
Deedar Singh Public U.M. Vidyalay
Jajau, Agra

Manager
Deedar Singh Public Uchchatar Madhyamik Vidyalaya



OHM LABORATORY PRIVATE LIMITED.

Certified By- ISO 9001:2015, ISO 45001:2018, ISO 14001:2015

Plot No.281, Udyog Kendra-II, Ecotech-3 Greater Noida, Uttar Pradesh, India-201306.

Tel: 0120-6552502, Cell +91-8130221266, 8368513734

E-mail: info.ohmlaboratory@gmail.com, Website: www.ohmlaboratory.com



TC-11080

TEST REPORT

Deedar Singh Public Uchchar Madhyamik Vidyalaya Jajau, Fatehpur Sikri, Kiraoli, Agra-283110	REPORT NO.	OHM20250612001
	ULR NO.	TC1108024300000141F
	SAMPLE ISSUE DATE	12/06/2025
	REPORT ISSUE DATE	16/06/2025

Sample Name	R O Water for drinking purpose
Quantity Received	Two Litre approx.
License Number	Not Mentioned
Batch No /Lot No.	Not Mentioned
Analysis Duration	12/06/2025 to 16/06/2025
Packing Condition	Good/Sealed
Sampled By	Sample collected by our lab representative from building premises

Analysis Report

Sr. No.	Test Parameters	Units	Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Organoleptic, Physical & Chemical Parameters						
1.	Color	Hazen	<1.0	5.0 Max.	15.0	IS 3025(P-4)
2.	Odour	--	Agreeable	Agreeable	Agreeable	IS 3025(P-5)
3.	Taste	--	Agreeable	Agreeable	Agreeable	IS 3025(P-8)
4.	Turbidity	NTU	<1.0	1.0 Max.	5.0	IS 3025(P-10)
5.	pH value	--	6.95	6.5-8.5	No Relaxation	IS 3025(P-11)
6.	Total Hardness (as CaCO ₃)	mg/L	48.0	200 Max.	600	IS 3025(P-21)
7.	Iron (as Fe)	mg/L	BDL(0.05)	1.0 Max.	No Relaxation	IS 3025(P-53)



Deedar Singh
Principal
Deedar Singh Public U.M. Vidyalay
Jajau, Agra

Page No.1/3

Urvashi
Manager
Deedar Singh Public Uchchar Madhyamik Vidyalaya

OHM LABORATORY PRIVATE LIMITED.

Certified By- ISO 9001:2015, ISO 45001:2018, ISO 14001:2015

Plot No.281, Udyog Kendra-II, Ecotech-3 Greater Noida, Uttar Pradesh, India-201306.

Tel: 0120-6552502, Cell +91-8130221266, 8368513734

E-mail: Info.ohmlaboratory@gmail.com, Website: www.ohmlaboratory.com



TEST REPORT

Deedar Singh Public Uchchatar Madhyamik Vidyalaya Jajau, Fatehpur Sikri, Kiraoli, Agra-283110	REPORT NO.	OHM20250612001
	ULR NO.	TC1108024300000141F
	SAMPLE ISSUE DATE	12/06/2025
	REPORT ISSUE DATE	16/06/2025


Sample Name	R O Water for drinking purpose
Quantity Received	Two Litre approx.
License Number	Not Mentioned
Batch No /Lot No.	Not Mentioned
Analysis Duration	12/06/2025 to 16/06/2025
Packing Condition	Good/Sealed
Sampled By	Sample collected by our lab representative from building premises

Analysis Report

Sr.No.	Test Parameters	Units	Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Organoleptic, Physical & Chemical Parameters						
8.	Fluoride (as F)	mg/L	0.04	1.0 Max.	1.5	IS 3025(P-60)
9.	Total Dissolved Solids	mg/L	128	500 Max.	2000	IS 3025(P-16)
10.	Chloride (as Cl)	mg/L	42.5	250 Max.	1000	IS 3025(P-32)
11.	Calcium (as Ca)	mg/L	12.0	75 Max.	200	IS 3025(P-40)
12.	Magnesium (as Mg)	mg/L	4.37	30 Max.	100	IS 3025(P-46)
13.	Nitrate (as NO ₃)	mg/L	<3.0	45 Max.	No Relaxation	IS 3025(P-34)
14.	Alkalinity (as CaCO ₃)	mg/L	38.0	200 Max.	600	IS 3025(P-24)

Page No.2/3




Principal
Deedar Singh Public U.M. Vidyalay
Jajau, Agra


Manager
Deedar Singh Public Uchchatar Madhyamik Vidyalaya

OHM LABORATORY PRIVATE LIMITED.

Certified By- ISO 9001:2015, ISO 45001:2018, ISO 14001:2015

Plot No.281, Udyog Kendra-II, Ecotech-3 Greater Noida, Uttar Pradesh, India-201306.

Tel: 0120-6552502, Cell +91-8130221266, 8368513734

E-mail: Info.ohmlaboratory@gmail.com, Website: www.ohmlaboratory.com

Analysis Report

Report No:OHM20250612001A

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
15.	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
16.	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

Remarks: The Tested Sample Conforms as per 10500:2012, with respect to above test only.

NOTE: 1) ND=Not Detected.

2) Figure in bracket indicates Limit of Quantification



Page No.3/3

*****End of Test Report*****

Deedar Singh
Principal
Deedar Singh Public U.M. Vidyalay
Jajau, Agra

Urvashi
Manager
Deedar Singh Public Uchchar Madhyamik Vidyalaya